



TYPE EXAMINATION CERTIFICATE

FIRE RESISTANCE OF LIFTS LANDING DOORS

Issued by Liftinstituut B.V.

- Certificate no. : NL09-400-1002-040-08 Revision no.: 2
- Description of the product : Fire resistant; Central opening, 2-panel lift landing door
- Trademark, type : HAS Asansör, HDCT 01
- Name and address of the manufacturer : HKS Has Asansör Kaucuk Plastik Metal Sanayi ve Ticaret A.Ş
Kale Mah. Ankara Cad. No.:77, Kestel
Bursa, Turkey
- Name and address of the certificate holder : HKS Has Asansör Kaucuk Plastik Metal Sanayi ve Ticaret A.Ş
Kale Mah. Ankara Cad. No.:77, Kestel
Bursa, Turkey
- Certificate issued on the following requirements : Lifts Directive 2014/33/EU
- Certificate based on the following standard : EN 81-58:2003
- Test laboratory : FIRES, s.r.o.
- Date and number of the laboratory report : October 30: 2009, FIRES-FR-144-09-AUNE
- Date of type examination : October 20: 2009
July 26 : 2017
- Classification
- | The performance criteria of the EN 81-58 covered are: | | |
|---|-----|----|
| | E | EW |
| Central opening, 2-panel lift landing door
HDCT 01 | 120 | 60 |
- Additional document with this certificate : Report belonging to the type examination certificate no.: NL 09-400-1002-040-08 rev.2
- Additional remarks : See report
- Conclusion : The lift landing door, type HDCT 01 meets the requirements of the Lift Directive, Annex I section 4.2 and the EN 81-58:2003, in particular for the classification indicated above.

Amsterdam

Date : 07-08-2017
Valid until : 07-08-2022ing. J.L. van Vliet
Managing Director

Certification decision by