

TYPE EXAMINATION **CERTIFICATE**

FIRE RESISTANCE OF LIFTS LANDING DOORS

Issued by Liftinstituut B.V.

Certificate no. : NL09-400-1002-040-08 Revision no.: 3

Description of the product : Fire resistant; Central opening, 2-panel lift landing door

Trademark : HAS Asansör

Type no. : HDCT 01

Name and address of the

manufacturer

: HKS Has Asansör Kaucuk Plastik Metal

Sanayi ve Ticaret A.Ş

Kale Mah. Ankara Cad. No.:77, Kestel

Bursa, Turkiye

Name and address of the

certificate holder

: HKS Has Asansör Kaucuk Plastik Metal

Sanayi ve Ticaret A.Ş

Kale Mah. Ankara Cad. No.:77, Kestel

Bursa, Turkiye

Certificate issued on the following requirements

Certificate based on the

following standard

: Lifts Directive 2014/33/EU

: EN 81-58:2018

Test laboratory : FIRES, s.r.o.

Date and number of the

laboratory report

: 30-10-2009, FIRES-FR-145-09-AUNE

Date of type examination : 08-07-2022

Classification

: The performance criteria of the EN 81-58 covered are: Ε EW Central opening, 2-panel lift landing door 120 60 HDCT 01

Additional document with this

certificate

: Report belonging to the type examination certificate

no.: NL 09-400-1002-040-08 rev.3

Additional remarks : See report.

This revision replaces certificate NL09-400-1002-040-08 rev. 2

of 07-08-2017

Conclusion

: The lift landing door, HDCT 01 meets the requirements of the

Lifts Directive, Annex I section 4.2 and the EN 81-58:2018, in

particular for the classification indicated above.

Amsterdam

Date : 08-07-2022 Valid until : 08-07-2027 ing A.J. van Ommen International Business Manager

Certification decision by



Report Type-examination

Report belonging to type-examination : NL09-400-1002-040-08

certificate no.

Date of issue of original certificate : 19-11-2009 Revision number / date 3 / 08-07-2022

Requirements : Lifts Directive 2014/33/EU

Standard: EN 81-58: 2018

Project no. : P220231

Examinations and tests

The type examination of the 2 panels central opening landing door model HCDT 01 existed from assessing the technical file and laboratory test report. The test was executed on 20-10-2009 at FIRES, s.r.o. Slovakia. All results for fire resistance are described in FIRES report no. FIRES-FR-145-09-AUNE. Liftinstituut recognizes the test and the results.

Report FIRES-FR-145-09-AUNE is part of this examination (see annex 1).

2. Results

After the final test the fire resistance results of the lift landing door were ranked in accordance with the requirements (classification) of the standard EN 81-58. See report FIRES-FR-145-09-AUNE Appendix No.1 for field of direct application of test results. In the assessment for revision 3, we additionally reviewed the validity of the existing report for EN 81-58:2018.



Conclusions

Based upon the results of the type-examination, Liftinstituut B.V. issues a certificate for the fire resistance of the HAS Asansör, 2 panels central opening lift landing door "HCDT 01".

The type-examination certificate is only valid for products which are in conformity with the same specifications as the type-certified product. Products deviating of these specifications need additional examination by Liftinstituut in order to determine whether a new type-examination certificate is necessary. Additional examination shall be requested by the certificate holder.

The type examination certificate is issued based on the requirements that are valid at the date of issue. Liftinstituut reserves all rights regarding the validity of the certificate with respect to changes in requirements or changes in state of the art of the product.

Prepared by:

Certification decision by:

Azaad Santoe Product specialist Certification



Annexes

Document(s) of the Technical File which were subject to the examination Annex 1.

Title:	Document number	Date
Report FR-145-09-AUNE2, 25 pages	FIRES-FR-145-09-AUNE	30-10-2009
Declaration letter FIRES	GM-004-22	22-06-2022

Overview of revisions of certificate and report Annex 2.

Rev.:	Date	Summary of revision
-	19-11-2009	Original
1	01-10-2015	Adaptations
2	02-08-2017	Update to Lifts Directive 2014/33/EU
3	08-07-2022	- Renewal of the certificate with another 5 years - Updated to EN 81-58:2018
		- Corrected FIRES report number in the certificate