

liftinstituut
SINCE 1933

TYPE EXAMINATION CERTIFICATE

FIRE RESISTANCE OF LIFTS LANDING DOORS

Issued by Liftinstituut B.V.

Certificate no. : NL09-400-1002-040-07 Revision no.: 3
Description of the product : Fire-resistant;
One side opening, 2-panel telescopic lift landing door
Trademark : HAS Asansör
Type no. : HDTL 01
Name and address of the manufacturer : HKS Has Asansör Kaucuk Plastik Metal
Sanayi ve Ticaret A.Ş.
Kale Mah. Ankara Cad. No.:77, Kestel
Bursa, Türkiye
Name and address of the certificate holder : HKS Has Asansör Kaucuk Plastik Metal
Sanayi ve Ticaret A.Ş.
Kale Mah. Ankara Cad. No.:77, Kestel
Bursa, Türkiye
Certificate issued on the following requirements : Lifts Directive 2014/33/EU
Certificate based on the following standard : EN 81-58:2018
Test laboratory : FIRES, s.r.o.
Date and number of the laboratory report : 30-10-2009, FIRES-FR-144-09-AUNE
Date of type examination : 07-07-2022

Classification

: The performance criteria of the EN 81-58 covered are:

	E	EW
One side opening, 2-panel telescopic landing door HDTL 01	120	60

Additional document with this certificate : Report belonging to the type examination certificate
no.: NL09-400-1002-040-07 rev.3

Additional remarks : See report.

This revision replaces certificate NL09-400-1002-040-07 rev. 2
of 07-08-2017

Conclusion

: The lift landing door HDTL 01 meets the requirements of the
Lifts Directive, Annex I section 4.2 and the EN 81-58:2018, in
particular for the classification indicated above.


Amsterdam

Date : 08-07-2022

Valid until : 08-07-2027

ing A.J. van Ommen
International Business
Manager

Certification decision by



liftinstituut
SINCE 1933

Report Type-examination

Report belonging to type-examination : NL09-400-1002-040-07
certificate no.
Date of issue of original certificate : 20-11-2009
Revision number / date : 3 / 08-07-2022
Requirements : Lifts Directive 2014/33/EU
Standard: EN 81-58:2018
Project no. : P220231


1. Examinations and tests

The type examination of the one side opening, 2-panel telescopic landing door HDTL 01 existed from assessing the technical file and laboratory test report. The test was executed on 20-10-2009 at FIRES, s.r.o. Slovakia. All results for fire resistance are described in FIRES report no. FIRES-FR-144-09-AUNE. Liftinstituut recognizes the test and the results.

Report FIRES-FR-144-09-AUNE is part of this examination (see Annex 1).

2. Results

After the final test the fire resistance results of the lift landing door were ranked in accordance with the requirements (classification) of the standard EN 81-58. See report FIRES-FR-144-09-AUNE Appendix No: 1 for field of direct application of test results. In the assessment for revision 3, we additionally reviewed the validity of the existing report for EN 81-58:2018.



liftinstituut
SINCE 1933

3. Conclusions

Based upon the results of the type-examination, Liftinstituut B.V. issues a certificate for the fire resistance of the HAS Asansör one side opening, 2-panel telescopic lift landing door "HDTL 01".


The type-examination certificate is only valid for products which are in conformity with the same specifications as the type-certified product. Products deviating of these specifications need additional examination by Liftinstituut in order to determine whether a new type-examination certificate is necessary. Additional examination shall be requested by the certificate holder.

The type examination certificate is issued based on the requirements that are valid at the date of issue. Liftinstituut reserves all rights regarding the validity of the certificate with respect to changes in requirements or changes in state of the art of the product.

Prepared by:

Azaad Santoe
Product specialist Certification

Certification decision by:



Annexes

Annex 1. : Document(s) of the Technical File which were subject to the examination

Title:	Document number	Date
Report FR-144-09-AUNE2, 25 pages	FIRES-FR-144-09-AUNE	30-10-2009
Declaration letter FIRES	GM-004-22	22-06-2022

Annex 2. : Overview of revisions of certificate and report

Rev.:	Date	Summary of revision
-	20-11-2009	Original
1	01-10-2015	Adaptations
2	02-08-2017	Update to Lifts Directive 2014/33/EU
3	08-07-2022	- Renewal of the certificate with another 5 years - Updated to EN 81-58:2018