

TYPE EXAMINATION CERTIFICATE

FIRE RESISTANCE OF LIFTS LANDING DOORS

Issued by Liftinstituut B.V.

Certificate no. : NL09-400-1002-040-07 Revision no.: 2

Description of the product : Fire resistant;
One side opening, 2-panel telescopic lift landing door

Trademark, type : HAS Asansör, HDTL 01

Name and address of the manufacturer : HKS Has Asansör Kaucuk Plastik Metal
Sanayi ve Ticaret A.Ş
Kale Mah. Ankara Cad. No.:77, Kestel
Bursa, Turkey

Name and address of the certificate holder : HKS Has Asansör Kaucuk Plastik Metal
Sanayi ve Ticaret A.Ş
Kale Mah. Ankara Cad. No.:77, Kestel
Bursa, Turkey

Certificate issued on the following requirements : Lifts Directive 2014/33/EU

Certificate based on the following standard : EN 81-58:2003

Test laboratory : FIRES, s.r.o.

Date and number of the laboratory report : October 30: 2009, FIRES-FR-144-09-AUNE

Date of type examination : October 20: 2009
July 26 : 2017

Classification

The performance criteria of the EN 81-58 covered are:

	E	EW
One side opening, 2-panel telescopic landing door HDTL 01	120	60

Additional document with this certificate : Report belonging to the type examination certificate no.: NL 09-400-1002-040-07 rev.2

Additional remarks : See report

Conclusion : The lift landing door, type HDTL 01 meets the requirements of the Lift Directive, Annex I section 4.2 and the EN 81-58:2003, in particular for the classification indicated above.

Amsterdam

Date : 07-08-2017
Valid until : 07-08-2022

ing. J.L. van Vliet
Managing Director

Certification decision by